

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.**

No. 714-2025Date : 20/06/2025

It is certified that an inspection team headed by Sunil Kumar
Junior Engineer (JE) G.B. Nagar (Name of Officers
with designation) from Jal Nigam (G.B. Nagar) (Name of
Department/Office) inspected the Thakur Khambeer Singh
Harpyari Devi public School Vill-uncha (Name & Address of
the School) on 16/06/2025 and found that the Thakur Khambeer
Singh Harpyari Devi public School (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of 15/06/2028



अवध अभियंता
जल निगम
(गौतम बुद्ध नगर)


Signature with Seal : _____


Name : Sunil Kumar
Designation : Jal Nigam (JE)
G.B. Nagar

To

Thakur Khambeer
Singh Harpyari Devi
public School Vill-uncha
Amipur G.B. Nagar.
(Name & Address of the Institution)


THAKUR KHAMBEER SINGH
HARPYARI DEVI PUBLIC SCHOOL
UNCHA AMIPUR (G. B. NAGAR)


प्रबंधक/सचिव
राज सिंह शिशौदिया शिक्षा समिति
एनटीपीसी ऊंचा अमीपुर गौतम बुद्ध नगर



SUPREME TEST HOUSE

Address: B-9, 2nd Floor, Sector 64, Noida, 201301

Mobile: +91-82658 94049 | +91-95993 42128

Website: www.supremetesthouse.com

Email: info@supremetesthouse.com

An ISO 9001:2015, ISO 14001:2015, ISO 45001:2018 Certified Laboratory



NABL ACCREDITED LABORATORY

TEST REPORT

Sample Name: Drinking water	Report No: STH/2025/06/16/04
Customer Name: Thakur Khambeer Singh Harpyari Devi Public School	Sample Quantity: 1 Ltr
Customer Address: Uncha Amipur dadri G.B Nagar (U.P).	Sample Condition : Good
ULR No.: TC14633025061604F	Temperature: 25°C±2
Sample Collected By : Mintu (From Lab)	Humidity : 55%±10
Sample Received On: 16/06/2025	Ref. No.: Nil.
Tested Location : At Laboratory	Duration of Testing: 16/06/2025-18/06/2025
	Reporting Date : 18/06/2025

S.No.	Test Parameter	Test Result	Requirement as per IS:10500:2012, Acceptable/Permissible Limit in the absence of alternate source	Test Method
Chemical Parameters				
1.)	Color, Hazen units	2	5/15	IS: 3025-(P-4)
2.)	Odour	Agreeable	Agreeable/ Agreeable	IS: 3025-(P-5)
3.)	pH @27°C	6.81	6.5-8.5/No relaxation	IS: 3025-(P-11)
4.)	Taste	Agreeable	Agreeable/ Agreeable	IS: 3025-(P-8)
5.)	Turbidity (NTU), Max.	<1	1/5	IS: 3025-(P-10)
6.)	T.D.S (mg/l), Max.	56	500/2000	IS: 3025-(P-16)
7.)	Total hardness (mg/l), Max.	28	200/600	IS: 3025-(P-21)
8.)	Chloride (mg/l), Max	7	250/1000	IS: 3025-(P-32)
9.)	Residual free chlorine (mg/l), Max	0.01	0.2/1	IS: 3025-(P-26)
10.)	Iron (mg/l), Max	0.010	1.0/No Relaxation	IS: 3025-(P-53)
11.)	Fluoride (mg/l), Max	0.012	1.0/1.5	IS: 3025-(P-60)
12.)	E.Coli Bacteria	Not detected	Shall not be detectable in any 100ml Sample	IS:1622-1981
13.)	Total Coliform Bacteria	Not detected	Shall not be detectable in any 100ml Sample	IS:1622-1981

End of Report

Page 1 of 1



Verified By (For Supreme Test House)

Arun Kumar

(Quality Manager)

THAKUR KHAMBEER SINGH
HARPYARI DEVI PUBLIC SCHOOL
UNCHA AMIPUR (G. B. NAGAR)

प्रबंधक/सचिव

Authorized signatory
Pradeep Bhardwaj
(Technical Manager)
रान सिंह शिशौदिया शिक्षा समिति
एनटीपीसी, ऊंचा अमीपुर गौतम बुद्ध नगर

Note: (1) The report refers only to the particular sample(s) submitted for testing. (2) This report shall not to be reproduced except in full without approval of the laboratory or in part and cannot be evidence in the court of Law. (3) Any discrepancy observed in the test report shall be brought in to the notice of the laboratory within week. (4) Results applied to the sample as received in the laboratory submitted by customer